



Republika ng Pilipinas
Republic of the Philippines
Kagawaran ng Tanggulang Pambansa
Department of National Defense
DNDPROPER BIDS AND AWARDS COMMITTEE

SUPPLEMENT BID BULLETIN NO. DND-P-2017-03-03

This Supplemental Bid Bulletin issued to amend, modify and/ or clarify items in the Bidding Documents for the **Procurement of CY 2017 DND Proper Aircon Maintenance Services (2nd Bidding)** of the Department of National Defense (DND)-Proper, as posted in the websites of the PhilGEPS and DND.

Please refer to the items as stated below.

NAME OF PROJECT	QUERY OF CONTINENTAL SALES, INC.	RESPONSE
Procurement of CY 2017 DND Proper Aircon Maintenance Services (2ND Bidding)	1. For package type air-conditioned, please tell us the exact number of Split Floor and Split Floor air-conditioned. a. Split Floor type – b. Split Wall Type –	1. For package type air-conditioned the exact number of Split floor type is fifty-nine (59) while Split wall type is fifty-one (51) (as shown below).
	2. For package/split type air-conditioned, do we need to pump down each units every air-conditioned cleaning.	2. Each package/split type aircon shall be pumped down in every quarterly cleaning.
	3. Do you have required time table to finish the cleaning for all the units?	3. Cleaning of 230 window type and 135 package/split type ACUs shall be done quarterly (w/in three months)
	4. Is there any required number of people to work in the area? We are planning to have 3 to 4 groups and each group consist a maximum of six (6) people.	4. The proponent shall provide enough manpower to complete the cleaning of 365 ACUS within the specified period (quarterly/ 3 months).

5. Can we work during weekends (Saturdays and Sundays) with extended hour from 7AM or 8AM to 6PM

6. How many building do we need to maintain in this project?

7. Can you please tell us how many units per building so we can determine the work load per building and the number of personnel needed during the cleaning air-conditioned? Please kindly include the number of floors per building.

5. **Cleaning shall be performed during office hours (8:00 AM to 5:00 PM, Mondays to Fridays) unless requested by some office that cleaning will be done during weekends.**

6. **Eleven (11) Buildings (as shown below)**

7. **Shown below is the detailed list of aircon per building:**

ACU		WT	SPLIT TYPE			TOTAL
DND Annexes			WM	CM	FM	
1	AS Building	12	3	6	3	44
2	DISG	33		1	7	41
3	Canteen	7				7
4	ODR	16			1	17
5	DAO	3			1	4
6	DNDTI	3		3	2	8
	CSC FO	4				4
7	PAS	3	3	2	2	10
	GYM			2		2
	Clinic	2	1		1	4
	Dorm A	1				1
	Dorm B	1				1
	Dorm C	4				4
	Dorm D	2				2
8	Motorpool	6	1			7
9	SND's Residence, FC	7	4		4	15
10	VIPSU	5		3		8
DND Building						
	Basement	15	2		1	18
	1 st Floor	37	3	2	11	53
	2 nd Floor	41	11		8	60
	3 rd Floor	28	15	6	17	66
	4 th Floor		8		1	9
	TOTAL	230	51	25	59	365


ASEC FELICITO VIRGILIO M. TRINIDAD, JR.
 Chairperson, DND-Proper BAC